


Avoid Direct Contact

Between Al Pipe and CONIC JOINT for AC on Indoor Unit Side

1. How to Install



AC Indoor Unit Side

Avoid direct contact between the aluminum tube and CONIC JOINT (the brass fitting) on the liquid line side by wrapping tape around the fitting or inserting cushioning material.

2. WHY IS IT IMPORTANT?

Direct contact between the aluminum tube and the brass fitting (CONIC JOINT) can cause **galvanic corrosion** and may result in refrigerant leakage.

